

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 160

Dated: 12/07/2024

It is certified that an inspection team head by **Tarun, Senior Chemist** from PHED inspected the **Gyaana International School, Budhkhan Road, Fatehpur, RamganjMandi** on **28/03/2024** and on the basis of Water Test Report (Attached) bearing no **PHED/Sr.Chemist/Lab/Chem/2023-2024/2236** dated **31/03/2024** of Office of the Senior Chemist PHED Regional Laboratory, Akelgarh, Kota, 324010, Certified that the **Gyaana International School** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid til 11/07/2027

Signature with Seal: 
Name:
Designation: सहायक अभियन्ता
Name & Address of the Office/ Department: जल स्वा. अभि. विभाग
ग्रामोण उपखण्ड रामगंजमंडी
कोटा - 32222

To
Gyaana International School,
RICCO Industrial Area, Budhkhan
Road, Fatehpur, RamganjMandi

OFFICE OF THE SENIOR CHEMIST
Public Health Engineering Department Regional Laboratory
AKELGARH KOTA - 324010 (Raj.)
REPORT OF THE CHEMICAL EXAMINATION OF WATER

PHED/Sr. Chemist/Lab/Chem/2023-2024/12236

Date 31/3/24

To Gyaana International School

District KOTA

R.I.D.O Industrial Area Budhkhaur Road Fatehpur Ramganj Mandi

Tehsil.....

Ref. :- Your letter No. GIS/24/83 Date 26.03.2024

Date of Examination 28.03.2024

Date of Receipt 26.03.2024

Name of Sample Taker Ram Singh Ji

Date of Collection 26.03.24

Code No.	<u>Urban</u>		
Particulars of Source	<u>At School Campus</u>		
Source	<u>R.O.</u>		
Village/Town	<u>Fatehpur R. Mandi</u>		
Lab Ref. No.	<u>PC-186</u>		
Note :- All Results Except pH are in mg/L			
PHYSICAL EXAMINATION			
1- pH	<u>8.08</u>		
2- Turbidity (NTU)	<u>0.19</u>		
3- Colour (Hazen Unit)	<u>-</u>		
4- Odour	<u>-</u>		
CHEMICAL EXAMINATION			
1- Alkalinity Phenolphthalein (CaCO ₃)	<u>-</u>		
2- Alkalinity Methyl Orange (CaCO ₃)	<u>24</u>		
3- Total Hardness (CaCO ₃)	<u>56</u>		
4- Calcium Hardness (CaCO ₃)	<u>-</u>		
5- Magnesium Hardness (as CaCO ₃)	<u>-</u>		
6- Chloride (as Cl ⁻)	<u>36</u>		
7- Sulphate (as SO ₄ ²⁻)	<u>-</u>		
8- Nitrite (as NO ₂ ⁻)	<u>-</u>		
9- Nitrate (as NO ₃ ⁻)	<u>3.04</u>		
10- Total Dissolved Solids	<u>125</u>		
11- Residual Chlorine	<u>-</u>		
12- Fluoride (as F ⁻)	<u>0.0628</u>		
13-	<u>-</u>		
14-	<u>-</u>		
15-	<u>-</u>		
16-	<u>-</u>		

Sample Not Collected by Lab

[Signature]
 Senior Chemist
 P.H.E.D. Regional Lab. Kota

Remarks :-
 PHED/Sr. Chemist/Lab./Chem/2023 - 2024/1

Date

- (1) Copy to S.E. PHED Circle, Kota
- (2) Copy to Ex. En. PHED Div.....

[Signature]
 Senior Chemist
 P.H.E.D. Regional Lab. Kota

OFFICE OF THE SENIOR CHEMIST
Public Health Engineering Department Regional Laboratory
AKELGARH KOTA - 324010 (Raj.)
BACTERIOLOGICAL EXAMINATION OF WATER

PHED/Lab./Sr. Chemist/Bact./2023.2024/2236

Date : 31/3/24

To,

Tehsil : Ramgarh Mandli

The Gyaana International School

District : Kota

R.I.C.O. Industrial Area, Budhkan Road,

Village : -

Fathepur, Ramgarh Mandli.

Reference: Your letter no. 83/26.3.24

Code No. : U

Name of Sample Taker: Sh. Ram Singh ji

sample Not Collected by Lab

Lab Sample Number	Date & Time of Collection	Date of Exam.	Residual Chlorine Mg/Lit.	Source	PARTICULARS OF SAMPLE	Coliform organism MPN/100 ML.	E coli organism MPN/100 ML.
18-140	26-3-24	26-3-24 to 28-3-24	-	RO	School Campus, R.I.C.O. Industrial Area, Budhkan Road, Fathepur, R. Mandli	Nil	


 Senior Chemist
 P.H.E.D. Regional Lab. Kota

PHED/Lab./Sr. Chemist/Bact/2023...-2024.....

Date

- Copy to
- (1) S.E., P.H.E.D., Circle, Kota
 - (2) Ex. En. P.H.E.D., Div.....
 - (3)

Senior Chemist
 P.H.E.D. Regional Lab. Kota